



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Jalkal Mayapur, Haridwar
Ph (O): 0134-226360, E-mail: eeujshrd@yahoo.com

TEST REPORT

Name and Address of Organization/ Customer	Jamdagni Public School, Pipli, Laksar, Haridwar Uttarakhand.		
Test Report ID	55/ UJS/DLWQTML/2026-27	Report Issue Date	09/06/2026
Date and Time of Sample Received:	05/06/2026 & 16:25	Sample Location	Village – pipli, laksar road haridwar.
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2026-27/55	Duration of Analysis	05/06/2026 to 08/06/2026

SN	Parameters	Test Method	Result	Requirements (Acceptable Limit) As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
(A) Organoleptic and Physical Parameters					
1.	pH at 25°C	IS 3025 (Part 11) 2022	7.26	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L	IS 3025 (Part 16), 2023	266	500 Max	2000 Max
3.	Turbidity, NTU	IS 3025 (Part 10), 2023	0.73	1 Max	5 Max
4.	Colour, CU	IS 3025 (Part 4): 2021	5	5 Max	15 Max
5.	Odour	IS 3025 (Part 5) : 2018	Agreeable	Agreeable	Agreeable
(B) General Parameters concerning substances					
6.	Total Alkalinity (as CaCO ₃), mg/L	IS 3025 (Part 23), 2023	140	200 Max	600 Max
7.	Total Hardness (as CaCO ₃), mg/L	IS 3025 (Part 21), 2009	172	200 Max	600 Max
8.	Calcium as Ca, mg/l	IS 3025 (Part 40), 2019	55.2	75 Max	200 Max
9.	Chloride as Cl, mg/L	IS 3025 (Part 32), 2025	11	250 Max	1000 Max
10.	Magnesium as Mg, mg/l	IS 3025:(Part46), 2023 (Volumetric Analysis EDTA)	8.26	30 Max	100 Max

Note:

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing Laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate. unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

(Er. Rakesh Chandra Bamrara)
Lab Incharge

जल कल अभियन्ता
उत्तराखण्ड जल संस्थान
हरिद्वार



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Jalkal Mayapur, Haridwar
Ph (O): 0134-226360, E-mail: eeujshrd@yahoo.com

TEST REPORT

Name and Address of Organization/ Customer	Jamdagni Public School, Pipli, Laksar, Haridwar Uttarakhand.		
Test Report ID	55/ UJS/DLWQTML/2026-27	Report Issue Date	09/06/2026
Date and Time of Sample Received:	05/06/2026 & 16:25	Sample Location	Village – pipli, laksar road haridwar.
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2026-27/55	Duration of Analysis	05/06/2026 to 08/06/2026

SN	Parameters	Test Method	Results	Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1.	Residual Free Chlorine, mg/L, Min	APHA 23rd Ed.-4500- CI-G	NA	0.2	1.0
Bacteriological Parameters					
2.	Total Coliform, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent
3.	E. coli, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent

Note:

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer.

**** End of Report****


(Er. Rakesh Chandra Bamrara)
Lab Incharge
जल कल अभियन्ता
उत्तराखण्ड जल संस्थान
हरिद्वार

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. NHM/26-27/ 49

Date : 10/6/2021

It is certified that an inspection team headed by Dr. Nalind Aswal
Medical Officer (Name of Officers
with designation) from CHC Laksa, dist. Nainital (Name of
Department/Office) inspected the Jamdagni public School,
Laksa (Name & Address of
the School) on 10/6/2021 and found that the Jamdagni Public
School, Laksa (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 year.

Signature with Seal : 

Name

: Dr. Nalind Aswal

Designation

: Medical Officer.

To

The Principal
Jamdagni Public School
Village Dipsi, Laksa, Nainital.

(Name & Address of the Institution)

अधीक्षक
साओ स्वाओ केन्द्र
लक्सा